



Supreme Stands  
for HVAC Equipment

18550 County Rd. 81  
Maple Grove, MN 55369  
763-428-3677


## 36" Unit Heater Wall Brackets

Ceiling Bracket not included

Used With:

UH22, UH21-R, UH28-R & UH24UNV ceiling bracket  
Ceiling bracket is bolted to upper arm of wall bracket  
Simply hook unit to upper bracket and tighten  
Hardware included with powder coat finish  
Rotates to any angle  
250 lb max

**Part Number: UHWB-36**



### Instructions:

1. Using 1/2" Lag bolts provided, bolt UHWB-36 securely to stud or solid up right wall. (very import to have this bolted securely.)
2. Using 3/8" x 2 1/2" bolt, bolt the support arm to UHWB-36.
3. Using 3/8" x 2 1/2" lag bolt, bolt support arm firmly to the wall.
4. Mount ceiling bracket to the UHWB-36 as shown in the picture.
5. Hang Unit Heat and turn to desired angle.

### Hardware:

- 3 1/2 x 5" lag bolts with washer
- 3 3/8 x 2 1/2" bolts with fender washer, washer & Nylock Nut
- 1 3/8 x 2 1/2" lag with washer